

Day	pH	Alk	Phos	Other	Y/N
1	8.07				Y
2	7.83				Y
3	8.13	80mg/L			Y
4	8.21				Y
5	8.16				Y
6	7.95				Y
7	8.03				Y
8	8.14				Y
9	8.02	100mg/L			Y
10	7.99				Y
11	8.21				Y
12	8.00				Y
13	7.24				Y
14	7.64				Y
15	7.31				Y
16	7.30				Y
17	7.64	120mg/L			Y
18	7.59				Y
19	8.22				Y
20	8.26				Y
21	7.61				Y
22	7.81				Y
23	8.04	80mg/L			Y
24	8.20				Y
25	7.99				Y
26	8.30				Y
27	8.34				Y
28	8.17				Y
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00783

System Name: ORCHARD HEIGHTS WATER ASSOCIATION

Entry Point: A

Sample Period: February 2025
Month/Year

Number of excursions* during this month: 9

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.00

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (-----)

Print Name: D. Douglas

Signature: [Signature]

Date: 2/28/2025

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 8