

Day	pH	Alk	Phos	Other	Y/N
1	8.09				Y
2	7.84				Y
3	7.79	80mg/L			Y
4	7.83				Y
5	7.73				Y
6	7.98				Y
7	7.78				Y
8	7.84				Y
9	7.91				Y
10	8.26	120mg/L			Y
11	7.74				Y
12	8.20				Y
13	7.76				Y
14	8.20				Y
15	8.02				Y
16	8.24				Y
17	7.81	80mg/L			Y
18	7.88				Y
19	7.94				Y
20	8.19				Y
21	8.11				Y
22	8.02				Y
23	8.10				Y
24	7.92	100mg/L			Y
25	8.02				Y
26	7.98				Y
27	8.12				Y
28	8.00	120mg/L			Y
29	7.97				Y
30	8.34				Y
31	7.25				Y

<<Have

minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

00783

System Name: ORLANDO HEIGHTS WATER ASSN

Entry Point: A

Sample Period: MARCH 2025

Month/Year

Number of excursions* during this month: 2
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 2
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality
Parameters as set by

pH

7.00

Alk

(Alkalinity)

PO4

(Orthophosphate)

Other

(_____)

Print Name: DON LOUIS

Signature: [Signature]

Date: 3/31/2025

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's