

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

| Day | pH   | Alk | Phos | Other | Y/N |
|-----|------|-----|------|-------|-----|
| 1   | 7.94 |     |      |       |     |
| 2   | 8.01 |     |      |       |     |
| 3   | 7.92 |     |      |       |     |
| 4   | 8.02 |     |      |       |     |
| 5   | 7.92 |     |      |       |     |
| 6   | 7.85 |     |      |       |     |
| 7   | 7.94 |     |      |       |     |
| 8   | 8.02 |     |      |       |     |
| 9   | 7.97 |     |      |       |     |
| 10  | 7.90 |     |      |       |     |
| 11  | 7.98 |     |      |       |     |
| 12  | 7.81 |     |      |       |     |
| 13  | 8.03 |     |      |       |     |
| 14  | 7.85 |     |      |       |     |
| 15  | 7.91 |     |      |       |     |
| 16  | 7.98 |     |      |       |     |
| 17  | 8.06 |     |      |       |     |
| 18  | 8.09 |     |      |       |     |
| 19  | 8.09 |     |      |       |     |
| 20  | 7.88 |     |      |       |     |
| 21  | 7.82 |     |      |       |     |
| 22  | 7.95 |     |      |       |     |
| 23  | 8.01 |     |      |       |     |
| 24  | 8.06 |     |      |       |     |
| 25  | 8.10 |     |      |       |     |
| 26  | 7.94 |     |      |       |     |
| 27  | 7.98 |     |      |       |     |
| 28  | 7.88 |     |      |       |     |
| 29  | 7.38 |     |      |       |     |
| 30  | 7.72 |     |      |       |     |
| 31  |      |     |      |       |     |

<<Have  
minimums  
been met for  
this day?

**ENTRY POINT**

PWS ID: 41

System Name: Orchard Heights Water Association

Entry Point: A

Sample Period: November 2025  
Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality  
Parameters as set by**

pH   
Alk  (Alkalinity)  
PO4  (Orthophosphate)  
Other  ( )

Print Name: Day First

Signature: [Signature]

Date: 12-2-2025

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's