

Day	pH	Alk	Phos	Other	'y'/N
1	7.06				Y
2	7.04				Y
3	7.04				Y
4	7.09				Y
5	7.13				Y
6	7.15				Y
7	7.10				Y
8	7.10				Y
9	7.10				Y
10	7.08				Y
11	7.06				Y
12	7.08				Y
13	7.10				Y
14	7.15				Y
15	7.35				Y
16	7.35				Y
17	7.38				Y
18	7.30				Y
19	7.37				Y
20	7.35				Y
21	7.44				Y
22	7.80				Y
23	7.79				Y
24	7.77				Y
25	7.90				Y
26	7.88				Y
27	7.87				Y
28	7.90				Y
29					
30					
31					

<<Have minimums been met for

ENTRY POINT

00783

this day? SWS ID' 41

System Name: Orchard Heights Water Assn.

Entry Point: A

Sample Period: FEB 2021 Month/Year

Number of excursions" during this month: 0
(Count the number of days when any WQP 'was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

—For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: David Simmons

Signature: [Signature]

Date: 3/2/21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's