

Day	pH	Alk	Phos	Other	y'/N
1	7.86				Y
2	7.83				Y
3	7.86				Y
4	7.83				Y
5	7.84				Y
6	7.83				Y
7	7.85				Y
8	7.85				Y
9	7.86				Y
10	7.87				Y
11	7.86				Y
12	7.84				Y
13	7.88				Y
14	7.83				Y
15	7.85				Y
16	7.85				Y
17	8.10				Y
18	8.04				Y
19	8.06				Y
20	7.95				Y
21	7.89				Y
22	8.16				Y
23	8.10				Y
24	8.06				Y
25	8.03				Y
26	8.06				X
27	8.08				X
28	8.05				Y
29	8.10				Y
30	8.06				Y
31	8.06				Y

<<Have minimums been met for

ENTRY POINT

00783

this day? SWS ID' 41

System Name: Orchard Heights Water Assn.

Entry Point: A

Sample Period: MARCH 2021 Month/Year

Number of excursions" during this month: 0
 (Count the number of days when any WQP 'was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

—For OHA use only —

Minimum Water Quality Parameters as set by

pH 7.0

Alk _____ (Alkalinity)

PO4 _____ (Orthophosphate)

Other _____ (_____)

Print Name: David Simmons

Signature: [Signature]

Date: 4/2/21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0