

Day	pH	Alk	Phos	Other	y'/N
1	8.10				Y
2	8.09				Y
3	8.02				Y
4	8.11				Y
5	8.09				Y
6	8.11				Y
7	8.02				Y
8	7.98				Y
9	7.95				Y
10	8.13				Y
11	8.08				Y
12	8.09				Y
13	8.06				Y
14	8.04				Y
15	8.10				Y
16	7.89				Y
17	8.11				Y
18	8.06				Y
19	8.06				Y
20	8.05				Y
21	8.05				Y
22	8.04				Y
23	8.05				Y
24	8.05				Y
25	8.06				Y
26	8.04				Y
27	8.04				Y
28	8.03				Y
29	8.04				Y
30	8.03				Y
31	8.80				Y

<<Have minimums been met for

ENTRY POINT

00783

this day? SWS ID' 41

System Name: Orchard Heights Water Assn.

Entry Point: A

Sample Period: May 2021
Month/Year

Number of excursions" during this month: 0
(Count the number of days when any WQP 'was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

—For OHA use only —

Minimum Water Quality Parameters as set by

pH 7.0
Alk _____ (Alkalinity)
PO4 _____ (Orthophosphate)
Other _____ (_____)

Print Name: David Simmons
Signature: [Signature]
Date: 6/4/21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

0