

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	'y'/N
1	8.71				Y
2	7.88				Y
3	7.86				Y
4	7.85				Y
5	7.81				Y
6	7.82				Y
7	7.82				Y
8	7.83				Y
9	7.92				Y
10	7.86				Y
11	7.91				Y
12	7.90				Y
13	7.88				Y
14	7.86				Y
15	7.87				Y
16	7.88				Y
17	7.87				Y
18	7.88				Y
19	7.87				Y
20	7.86				Y
21	7.78				Y
22	7.78				Y
23	7.77				Y
24	7.75				Y
25	7.81				Y
26	7.73				Y
27	7.69				Y
28	7.60				Y
29	7.59				Y
30	7.66				Y
31					

<<Have minimums been met for

ENTRY POINT

00783

this day? SWS ID' 41

System Name: Orchard Heights Water Assn.

Entry Point: A

Sample Period: June 2021

 Month/Year

Number of excursions" during this month: 0
 (Count the number of days when any WQP 'was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

—For OHA use only —

Minimum Water Quality Parameters as set by

pH 7.0
 Alk _____ (Alkalinity)
 PO4 _____ (Orthophosphate)
 Other _____ (_____)

Print Name: David Simmons

Signature: [Signature]

Date: 7/3/2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0