

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control



Entry Point B

Day	pH	Alk	Phos other	Y/N
5/1/21	8.0			Yes
5/2/21	8.0	18.4		Yes
5/3/21	8.1			Yes
5/4/21	7.8			Yes
5/5/21	7.9			Yes
5/6/21	8.2			Yes
5/7/21	8.0			Yes
5/8/21	7.9			Yes
5/9/21	8.0			Yes
5/10/21	7.9			Yes
5/11/21	7.8			Yes
5/12/21	7.8			Yes
5/13/21	7.9			Yes
5/14/21	7.9			Yes
5/15/21	7.9	17.5		Yes
5/16/21	7.9			Yes
5/17/21	7.8			Yes
5/18/21	7.8			Yes
5/19/21	7.8			Yes
5/20/21	8.2			Yes
5/21/21	8.0			Yes
5/22/21	8.0			Yes
5/23/21	8.0			Yes
5/24/21	8.0			Yes
5/25/21	7.9			Yes
5/26/21	8.1			Yes
5/27/21	8.0			Yes
5/28/21	7.8			Yes
5/29/21	8.0			Yes
5/30/21	8.1			Yes
5/31/21	8.1	18.5		Yes

PWSID 4100786
 System name Skyview Acres Water Co-op
 Entry Point EP-B EP City of Sandy
 Sample Period May-21

Number of excursionsn during this month 0
 (count the number of days when any WQP was
 less than minimum required)

Total excursion during the previous 5 months 0
 (Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are
 culmulative)

For OHA use only

Minimum Water Quality	
Parameters as set by	State
pH	7.8
Alk	15 Alkanlinity
PO4	Orthrophosphate
Other	

Print Name David Jacob
 Signature David Jacob
 Date 6/7/2021