

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos	other	Y/N
2/1/22	8.08				Yes
2/2/22	8.06				Yes
2/3/22	8.20				Yes
2/4/22	8.20				Yes
2/5/22	8.27				Yes
2/6/22	8.23				Yes
2/7/22	8.05				Yes
2/8/22	7.83				Yes
2/9/22	7.76				No
2/10/22	7.76				No
2/11/22	8.16				Yes
2/12/22	8.72				Yes
2/13/22	8.78				Yes
2/14/22	8.76				Yes
2/15/22	8.49				Yes
2/16/22	8.42				Yes
2/17/22	8.42				Yes
2/18/22	8.37				Yes
2/19/22	8.37				Yes
2/20/22	8.35				Yes
2/21/22	8.34				Yes
2/22/22	8.21				Yes
2/23/22	7.81				Yes
2/24/22	7.74				No
2/25/22	7.71				No
2/26/22	7.66				No
2/27/22	7.70				No
2/28/22	8.44				Yes



Entry Point B

PWSID	4100786
System name	Skyview Acres Water Co-op
Entry Point	EP-B EP City of Sandy
Sample Period	Feb-22
Number of excursionsn during this month (count the number of days when any WQP was less than minimum required)	6
Total excursion during the previous 5 months	0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative	
For OHA use only	
Minimum Water Quality Parameters as set by State	
pH	7.8
Alk	15 Alkanlinity
PO4	Orthrophosphate
Other	

Print Name David Jacob
 Signature David Jacob
 Date 3/9/2022