

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
4/1/22	8.690	25.3		Yes
4/2/22	8.740			Yes
4/3/22	8.730			Yes
4/4/22	8.740			Yes
4/5/22	8.730			Yes
4/6/22	8.710			Yes
4/7/22	8.720			Yes
4/8/22	8.680			Yes
4/9/22	8.630	19		Yes
4/10/22	8.660			Yes
4/11/22	8.680			Yes
4/12/22	8.690			Yes
4/13/22	8.650			Yes
4/14/22	8.580			Yes
4/15/22	8.570			Yes
4/16/22	8.620	18.7		Yes
4/17/22	8.590			Yes
4/18/22	8.600			Yes
4/19/22	8.580			Yes
4/20/22	8.160			Yes
4/21/22	8.540			Yes
4/22/22	8.480	17.5		Yes
4/23/22	8.550			Yes
4/24/22	8.550			Yes
4/25/22	8.530			Yes
4/26/22	8.680			Yes
4/27/22	8.670			Yes
4/28/22	8.650			Yes
4/29/22	8.690	19.3		Yes
4/30/22	8.750			Yes

Entry Point B

PWSID 4100786
 System name Skyview Acres Water Co-op
 Entry Point EP-B EP City of Sandy
 Sample Period Apr-22

Number of excursionsn during this month 0
 (count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 6
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative)

For OHA use only

Minimum Water Quality Parameters as set by	State
pH	7.8
Alk	15 Alkanlinity
PO4	Orthrophosphate
Other	

Print Name David Jacob
 Signature David Jacob
 Date 5/4/2022