

# Water Quality Parameter Monitoring Form

## Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
5/1/22	8.72			Yes
5/2/22	8.73			Yes
5/3/22	8.73			Yes
5/4/22	8.74			Yes
5/5/22	8.78			Yes
5/6/22	8.61	18.2		Yes
5/7/22	8.57			Yes
5/8/22	8.58			Yes
5/9/22	8.65			Yes
5/10/22	8.64			Yes
5/11/22	8.71			Yes
5/12/22	8.51			Yes
5/13/22	8.52	19.9		Yes
5/14/22	8.77			Yes
5/15/22	8.77			Yes
5/16/22	8.79			Yes
5/17/22	8.78			Yes
5/18/22	8.78			Yes
5/19/22	8.71			Yes
5/20/22	8.75	20.4		Yes
5/21/22	8.77			Yes
5/22/22	8.75			Yes
5/23/22	8.78			Yes
5/24/22	8.75			Yes
5/25/22	8.80			Yes
5/26/22	8.80			Yes
5/27/22	8.80	21		Yes
5/28/22	8.77			Yes
5/29/22	8.74			Yes
5/30/22	8.70			Yes
5/31/22	8.67			Yes

### Entry Point B

PWSID 4100786  
System name Skyview Acres Water Co-op  
Entry Point EP-B EP City of Sandy  
Sample Period May-22

Number of excursionsn during this month 0  
(count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 6  
(Over 9 excursions in 6 months is a violation.  
Entry Point and Distribution excursions are culmulative

For OHA use only

Minimum Water Quality Parameters as set by State  
pH 7.8  
Alk 15 Alkanlinity  
PO4 Orthrophosphate  
Other

Print Name David Jacob  
Signature David Jacob  
Date 6/2/2022