

# Water Quality Parameter Monitoring Form

## Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
9/1/22	8.92			Yes
9/2/22	8.99	26.4		Yes
9/3/22	8.99			Yes
9/4/22	9.03			Yes
9/5/22	9.02			Yes
9/6/22	8.98			Yes
9/7/22	8.86			Yes
9/8/22	8.78			Yes
9/9/22	8.89	23.3		Yes
9/10/22	8.89			Yes
9/11/22	8.85			Yes
9/12/22	8.92			Yes
9/13/22	8.72			Yes
9/14/22	8.50			Yes
9/15/22	8.63			Yes
9/16/22	8.79	28.9		Yes
9/17/22	8.70			Yes
9/18/22	8.48			Yes
9/19/22	8.30			Yes
9/20/22	8.58			Yes
9/21/22	8.64			Yes
9/22/22	8.66			Yes
9/23/22	8.49	32.2		Yes
9/24/22	8.64			Yes
9/25/22	8.61			Yes
9/26/22	8.71			Yes
9/27/22	8.63			Yes
9/28/22	8.63			Yes
9/29/22	8.55			Yes
9/30/22	8.50	25.5		Yes

### Entry Point B

PWSID 4100786

System name Skyview Acres Water Co-op

Entry Point EP-B EP City of Sandy

Sample Period Sep-22

Number of excursionsn during this month 0  
(count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative)

For OHA use only

Minimum Water Quality Parameters as set by		State
pH	7.8	
Alk	15	Alkanlinity
PO4		Orthrophosphate
Other		

Print Name

David Jacob

Signature

*David Jacob*

Date

10/4/2022