

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

| Day | pH | Alk | Phos | other | Y/N |
|----------|------|------|------|-------|-----|
| 11/1/22 | 8.63 | | | | Yes |
| 11/2/22 | 8.64 | | | | Yes |
| 11/3/22 | 8.63 | | | | Yes |
| 11/4/22 | 8.6 | 26.6 | | | Yes |
| 11/5/22 | 8.09 | | | | Yes |
| 11/6/22 | 8.01 | | | | Yes |
| 11/7/22 | 8.11 | | | | Yes |
| 11/8/22 | 8.16 | | | | Yes |
| 11/9/22 | 8.15 | | | | Yes |
| 11/10/22 | 8.34 | | | | Yes |
| 11/11/22 | 8.53 | 23.9 | | | Yes |
| 11/12/22 | 8.73 | | | | Yes |
| 11/13/22 | 8.81 | | | | Yes |
| 11/14/22 | 8.82 | | | | Yes |
| 11/15/22 | 8.7 | | | | Yes |
| 11/16/22 | 8.96 | | | | Yes |
| 11/17/22 | 9.03 | | | | Yes |
| 11/18/22 | 8.99 | 22.2 | | | Yes |
| 11/19/22 | 8.97 | | | | Yes |
| 11/20/22 | 9.05 | | | | Yes |
| 11/21/22 | 9.15 | | | | Yes |
| 11/22/22 | 9.17 | | | | Yes |
| 11/23/22 | 9.2 | | | | Yes |
| 11/24/22 | 9.22 | | | | Yes |
| 11/25/22 | 9.18 | 29.3 | | | Yes |
| 11/26/22 | 9.14 | | | | Yes |
| 11/27/22 | 9.14 | | | | Yes |
| 11/28/22 | 9.16 | | | | Yes |
| 11/29/22 | 9.15 | | | | Yes |
| 11/30/22 | 9.14 | | | | Yes |

Entry Point B

PWSID 4100786
System name Skyview Acres Water Co-op
Entry Point EP-B EP City of Sandy
Sample Period Nov-22

Number of excursionsn during this month 0
(count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 1
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative)

For OHA use only

| Minimum Water Quality Parameters as set by State | | State |
|--|--|-----------------|
| pH | | 7.8 |
| Alk | | 15 Alkanlinity |
| PO4 | | Orthrophosphate |
| Other | | |

Print Name

David Jacob

Signature

David Jacob

Date

12/4/2022