

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
1/1/23	8.96			Yes
1/2/23	9.23	21.1		Yes
1/3/23	9.01			Yes
1/4/23	8.86			Yes
1/5/23	8.80			Yes
1/6/23	8.87	24.3		Yes
1/7/23	9.06			Yes
1/8/23	9.06			Yes
1/9/23	9.05			Yes
1/10/23	9.12			Yes
1/11/23	9.04			Yes
1/12/23	9.04			Yes
1/13/23	9.08	20.1		Yes
1/14/23	9.07			Yes
1/15/23	9.09			Yes
1/16/23	8.85			Yes
1/17/23	8.67			Yes
1/18/23	8.60			Yes
1/19/23	8.50			Yes
1/20/23	8.61	19.6		Yes
1/21/23	8.57			Yes
1/22/23	8.49			Yes
1/23/23	8.42			Yes
1/24/23	8.53			Yes
1/25/23	8.42			Yes
1/26/23	8.37			Yes
1/27/23	8.42	22		Yes
1/28/23	8.84			Yes
1/29/23	8.96			Yes
1/30/23	8.63			Yes
1/31/23	8.86			Yes

Entry Point B

PWSID 4100786
System name Skyview Acres Water Co-op
Entry Point EP-B EP City of Sandy
Sample Period Jan-23

Number of excursionsn during this month 0
(count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0
(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are culmulative 1

For OHA use only

Minimum Water Quality Parameters as set by State

pH 7.8

Alk 15 Alkanlinity

PO4 Orthrophosphate

Other

Print Name David Jacob

Signature David Jacob

Date 2/5/2023