

# Water Quality Parameter Monitoring Form

## Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
2/1/23	8.79			Yes
2/2/23	8.85			Yes
2/3/23	8.90			Yes
2/4/23	8.82	26.4		Yes
2/5/23	8.89			Yes
2/6/23	8.84			Yes
2/7/23	8.83			Yes
2/8/23	8.72			Yes
2/9/23	8.72			Yes
2/10/23	8.69	22.9		Yes
2/11/23	8.33			Yes
2/12/23	8.08			Yes
2/13/23	8.10			Yes
2/14/23	8.25			Yes
2/15/23	8.39			Yes
2/16/23	8.31			Yes
2/17/23	8.43	20.5		Yes
2/18/23	8.41			Yes
2/19/23	8.48			Yes
2/20/23	8.36			Yes
2/21/23	8.32			Yes
2/22/23	8.39			Yes
2/23/23	8.38			Yes
2/24/23	8.94	21.6		Yes
2/25/23	9.15			Yes
2/26/23	9.16			Yes
2/27/23	9.15			Yes
2/28/23	8.93			Yes

### Entry Point B

PWSID 4100786  
System name Skyview Acres Water Co-op  
Entry Point EP-B EP City of Sandy  
Sample Period Feb-23

Number of excursionsn during this month 0  
(count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0  
(Over 9 excursions in 6 months is a violation.  
Entry Point and Distribution excursions are culmulative 1

For OHA use only

Minimum Water Quality Parameters as set by State  
pH 7.8  
Alk 15 Alkanlinity  
PO4 Orthrophosphate  
Other

Print Name David Jacob  
Signature David Jacob  
Date 3/2/2023