

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
3/1/23	8.8			Yes
3/2/23	8.8			Yes
3/3/23	9.0	19.8		Yes
3/4/23	9.1			Yes
3/5/23	8.8			Yes
3/6/23	8.8			Yes
3/7/23	8.8			Yes
3/8/23	8.7			Yes
3/9/23	8.6			Yes
3/10/23	8.8	25.5		Yes
3/11/23	8.8			Yes
3/12/23	8.7			Yes
3/13/23	8.7			Yes
3/14/23	8.8			Yes
3/15/23	8.6			Yes
3/16/23	8.6			Yes
3/17/23	8.7	19.9		Yes
3/18/23	8.6			Yes
3/19/23	8.6			Yes
3/20/23	8.6			Yes
3/21/23	8.6			Yes
3/22/23	8.7			Yes
3/23/23	8.5			Yes
3/24/23	8.5	20.3		Yes
3/25/23	8.5			Yes
3/26/23	8.6			Yes
3/27/23	8.6			Yes
3/28/23	8.5			Yes
3/29/23	8.6			Yes
3/30/23	8.4			Yes
3/31/23	8.4	22.2		Yes

Entry Point B

PWSID 4100786
System name Skyview Acres Water Co-op
Entry Point EP-B EP City of Sandy
Sample Period Mar-23

Number of excursionsn during this month 0
(count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 1
(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are culmulative

For OHA use only

Minimum Water Quality Parameters as set by State
pH 7.8
Alk 15 Alkanlinity
PO4 Orthrophosphate
Other

Print Name David Jacob
Signature David Jacob
Date 4/4/2023