

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
5/1/23	8.78			Yes
5/2/23	8.76			Yes
5/3/23	8.74			Yes
5/4/23	8.69	28.5		Yes
5/5/23	8.78			Yes
5/6/23	8.80			Yes
5/7/23	8.87			Yes
5/8/23	9.02			Yes
5/9/23	8.96			Yes
5/10/23	8.96			Yes
5/11/23	8.98			Yes
5/12/23	9.31	23		Yes
5/13/23	9.28			Yes
5/14/23	9.26			Yes
5/15/23	9.18			Yes
5/16/23	9.12			Yes
5/17/23	8.99			Yes
5/18/23	9.18			Yes
5/19/23	9.12	21.2		Yes
5/20/23	9.30			Yes
5/21/23	8.88			Yes
5/22/23	8.82			Yes
5/23/23	8.95			Yes
5/24/23	8.95			Yes
5/25/23	9.09			Yes
5/26/23	9.29			Yes
5/27/23	9.27	26.4		Yes
5/28/23	9.09			Yes
5/29/23	9.12			Yes
5/30/23	8.78			Yes
5/31/23	9.01			Yes

Entry Point B

PWSID 4100786
System name Skyview Acres Water Co-op
Entry Point EP-B EP City of Sandy
Sample Period May-23

Number of excursionsn during this month 0
(count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are culmulative

For OHA use only

Minimum Water Quality Parameters as set by State

pH 7.8

Alk 15 Alkanlinity

PO4 Orthrophosphate

Other

Print Name David Jacob

Signature David Jacob

Date 6/7/2023