

# Water Quality Parameter Monitoring Form

## Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
11/1/23	9.29			Yes
11/2/23	9.29			Yes
11/3/23	9.29	24.2		Yes
11/4/23	9.28			Yes
11/5/23	9.28			Yes
11/6/23	9.28			Yes
11/7/23	9.26			Yes
11/8/23	9.26			Yes
11/9/23	9.26			Yes
11/10/23	9.25	24.7		Yes
11/11/23	9.26			Yes
11/12/23	9.26			Yes
11/13/23	9.25			Yes
11/14/23	9.25			Yes
11/15/23	9.25			Yes
11/16/23	9.25			Yes
11/17/23	9.25	26.7		Yes
11/18/23	9.25			Yes
11/19/23	9.25			Yes
11/20/23	9.24			Yes
11/21/23	9.22			Yes
11/22/23	9.22			Yes
11/23/23	9.22			Yes
11/24/23	8.37	24.9		Yes
11/25/23	8.35			Yes
11/26/23	8.36			Yes
11/27/23	8.75			Yes
11/28/23	8.62			Yes
11/29/23	8.2			Yes
11/30/23	9.44			Yes

### Entry Point B

PWSID 4100786

System name Skyview Acres Water Co-op

Entry Point EP-B EP City of Sandy

Sample Period Nov-23

Number of excursionsn during this month 0  
(count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative)

For OHA use only

Minimum Water Quality Parameters as set by State State

pH 7.8

Alk 15 Alkanlinity

PO4 Orthrophosphate

Other

Print Name

David Jacob

Signature

*David Jacob*

Date

12/5/2023