

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
2/1/24	8.74			Yes
2/2/24	8.74	22.5		Yes
2/3/24	9.00			Yes
2/4/24	8.96			Yes
2/5/24	8.83			Yes
2/6/24	8.87			Yes
2/7/24	8.96			Yes
2/8/24	8.96			Yes
2/9/24	8.90	21.6		Yes
2/10/24	8.94			Yes
2/11/24	8.90			Yes
2/12/24	8.77			Yes
2/13/24	8.86			Yes
2/14/24	8.70			Yes
2/15/24	8.89			Yes
2/16/24	8.84	22.9		Yes
2/17/24	8.77			Yes
2/18/24	8.85			Yes
2/19/24	8.80			Yes
2/20/24	8.85			Yes
2/21/24	8.79			Yes
2/22/24	8.88	27.1		Yes
2/23/24	8.82			Yes
2/24/24	8.70			Yes
2/25/24	8.80			Yes
2/26/24	8.67			Yes
2/27/24	8.79			Yes
2/28/24	8.76			Yes
2/29/24	8.73			Yes

Entry Point B

PWSID 4100786

System name Skyview Acres Water Co-op

Entry Point EP-B EP City of Sandy

Sample Period Feb-24

Number of excursionsn during this month 0
(count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are culmulative 0

For OHA use only

Minimum Water Quality Parameters as set by State

pH 7.8

Alk 15 Alkanlinity

PO4 Orthrophosphate

Other

Print Name David Jacob

Signature David Jacob

Date 3/3/2024