

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

| Day     | pH    | Alk  | Phos other | Y/N |
|---------|-------|------|------------|-----|
| 4/1/24  | 8.720 |      |            | Yes |
| 4/2/24  | 8.690 |      |            | Yes |
| 4/3/24  | 8.430 |      |            | Yes |
| 4/4/24  | 8.320 |      |            | Yes |
| 4/5/24  | 8.400 | 19.3 |            | Yes |
| 4/6/24  | 8.380 |      |            | Yes |
| 4/7/24  | 8.310 |      |            | Yes |
| 4/8/24  | 8.260 |      |            | Yes |
| 4/9/24  | 8.270 |      |            | Yes |
| 4/10/24 | 8.300 |      |            | Yes |
| 4/11/24 | 8.360 |      |            | Yes |
| 4/12/24 | 8.340 | 18.2 |            | Yes |
| 4/13/24 | 8.290 |      |            | Yes |
| 4/14/24 | 8.320 |      |            | Yes |
| 4/15/24 | 8.210 |      |            | Yes |
| 4/16/24 | 8.540 |      |            | Yes |
| 4/17/24 | 8.590 |      |            | Yes |
| 4/18/24 | 8.580 |      |            | Yes |
| 4/19/24 | 8.610 | 23.2 |            | Yes |
| 4/20/24 | 8.650 |      |            | Yes |
| 4/21/24 | 8.570 |      |            | Yes |
| 4/22/24 | 8.710 |      |            | Yes |
| 4/23/24 | 8.750 |      |            | Yes |
| 4/24/24 | 8.870 |      |            | Yes |
| 4/25/24 | 8.860 |      |            | Yes |
| 4/26/24 | 8.740 | 23.4 |            | Yes |
| 4/27/24 | 8.640 |      |            | Yes |
| 4/28/24 | 8.580 |      |            | Yes |
| 4/29/24 | 8.630 |      |            | Yes |
| 4/30/24 | 8.630 |      |            | Yes |

Entry Point B

PWSID 4100786  
 System name Skyview Acres Water Co-op  
 Entry Point EP-B EP City of Sandy  
 Sample Period Apr-24

Number of excursionsn during this month 0  
 (count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative 0)

For OHA use only

|  |                 |
|--|-----------------|
| Minimum Water Quality Parameters as set by | State           |
| pH   | 7.8             |
| Alk  | 15 Alkanlinity  |
| PO4  | Orthrophosphate |
| Other                                      |                 |

Print Name David Jacob  
 Signature David Jacob  
 Date 5/5/2024