

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
5/1/24	8.60			Yes
5/2/24	8.64			Yes
5/3/24	8.60	25.4		Yes
5/4/24	8.59			Yes
5/5/24	8.66			Yes
5/6/24	8.56			Yes
5/7/24	8.56			Yes
5/8/24	8.62			Yes
5/9/24	8.68			Yes
5/10/24	8.63	23.1		Yes
5/11/24	8.78			Yes
5/12/24	8.77			Yes
5/13/24	8.77			Yes
5/14/24	8.70			Yes
5/15/24	8.69			Yes
5/16/24	8.69			Yes
5/17/24	8.74	19.8		Yes
5/18/24	8.70			Yes
5/19/24	8.75			Yes
5/20/24	8.64			Yes
5/21/24	8.63			Yes
5/22/24	8.65			Yes
5/23/24	8.69			Yes
5/24/24	8.82	24.4		Yes
5/25/24	8.78			Yes
5/26/24	8.76			Yes
5/27/24	8.72			Yes
5/28/24	8.76			Yes
5/29/24	8.78			Yes
5/30/24	8.78			Yes
5/31/24	8.64	25.1		Yes

Entry Point B

PWSID 4100786  
 System name Skyview Acres Water Co-op  
 Entry Point EP-B EP City of Sandy  
 Sample Period May-24

Number of excursionsn during this month 0  
 (count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative) 0

For OHA use only

Minimum Water Quality Parameters as set by	State
pH	7.8
Alk	15 Alkanlinity
PO4	Orthrophosphate
Other	

Print Name David Jacob

Signature David Jacob  
 Date 6/9/2024