

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
6/1/24	8.62			Yes
6/2/24	8.60			Yes
6/3/24	8.54			Yes
6/4/24	8.59			Yes
6/5/24	8.52			Yes
6/6/24	8.50			Yes
6/7/24	8.55			Yes
6/8/24	8.52	24.8		Yes
6/9/24	8.52			Yes
6/10/24	8.50			Yes
6/11/24	8.57			Yes
6/12/24	8.53			Yes
6/13/24	8.54			Yes
6/14/24	8.52	28.8		Yes
6/15/24	8.50			Yes
6/16/24	8.51			Yes
6/17/24	8.43			Yes
6/18/24	8.37			Yes
6/19/24	8.41			Yes
6/20/24	8.40			Yes
6/21/24	8.35	21.7		Yes
6/22/24	8.40			Yes
6/23/24	8.43			Yes
6/24/24	8.42			Yes
6/25/24	8.55			Yes
6/26/24	8.61			Yes
6/27/24	8.60			Yes
6/28/24	8.61	25.3		Yes
6/29/24	8.74			Yes
6/30/24	8.75			Yes

Entry Point B

PWSID 4100786
 System name Skyview Acres Water Co-op
 Entry Point EP-B EP City of Sandy
 Sample Period Jun-24

Number of excursionsn during this month 0
 (count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months
 (Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are culmulative 0

For OHA use only

Minimum Water Quality Parameters as set by	State
pH	7.8
Alk	15 Alkanlinity
PO4	Orthrophosphate
Other	

Print Name David Jacob
 Signature David Jacob
 Date 7/6/2024