

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
7/1/24	8.7			Yes
7/2/24	8.7			Yes
7/3/24	8.8			Yes
7/4/24	8.7			Yes
7/5/24	8.7			Yes
7/6/24	8.7	28.1		Yes
7/7/24	8.8			Yes
7/8/24	8.7			Yes
7/9/24	8.7			Yes
7/10/24	8.7			Yes
7/11/24	8.7			Yes
7/12/24	8.8			Yes
7/13/24	8.9	30.1		Yes
7/14/24	8.9			Yes
7/15/24	8.8			Yes
7/16/24	8.8			Yes
7/17/24	8.8			Yes
7/18/24	8.7			Yes
7/19/24	8.6			Yes
7/20/24	8.7	26.5		Yes
7/21/24	8.7			Yes
7/22/24	8.7			Yes
7/23/24	8.6			Yes
7/24/24	8.6			Yes
7/25/24	8.4			Yes
7/26/24	8.8	26.3		Yes
7/27/24	8.8			Yes
7/28/24	8.7			Yes
7/29/24	8.7			Yes
7/30/24	8.6			Yes
7/31/24	8.5			Yes

Entry Point B

PWSID 4100786
 System name Skyview Acres Water Co-op
 Entry Point EP-B EP City of Sandy
 Sample Period Jul-24

Number of excursionsn during this month 0
 (count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative) 0

For OHA use only

Minimum Water Quality Parameters as set by	State
pH	7.8
Alk	15 Alkanlinity
PO4	Orthrophosphate
Other	

Print Name David Jacob

Signature David Jacob
 Date 8/4/2024