

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
9/1/24	8.39			Yes
9/2/24	8.42			Yes
9/3/24	8.43			Yes
9/4/24	8.25			Yes
9/5/24	8.29			Yes
9/6/24	8.33	23.1		Yes
9/7/24	8.74			Yes
9/8/24	8.70			Yes
9/9/24	8.73			Yes
9/10/24	8.70			Yes
9/11/24	8.72			Yes
9/12/24	8.72			Yes
9/13/24	8.65	24.4		Yes
9/14/24	8.53			Yes
9/15/24	8.56			Yes
9/16/24	8.53			Yes
9/17/24	8.50			Yes
9/18/24	8.49			Yes
9/19/24	8.46			Yes
9/20/24	8.43	23.8		Yes
9/21/24	8.48			Yes
9/22/24	8.44			Yes
9/23/24	8.41			Yes
9/24/24	8.36			Yes
9/25/24	8.33			Yes
9/26/24	8.45			Yes
9/27/24	8.69	29.2		Yes
9/28/24	8.69			Yes
9/29/24	8.66			Yes
9/30/24	8.65			Yes

Entry Point B

PWSID 4100786
 System name Skyview Acres Water Co-op
 Entry Point EP-B EP City of Sandy
 Sample Period Sep-24

Number of excursionsn during this month 0
 (count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative) 0

For OHA use only

Minimum Water Quality Parameters as set by	State
pH	7.8
Alk	15 Alkanlinity
PO4	Orthrophosphate
Other	

Print Name David Jacob
 Signature David Jacob
 Date 10/6/2024