

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
1/1/25	8.90			Yes
1/2/25	8.84			Yes
1/3/25	8.84	7:12		Yes
1/4/25	8.82			Yes
1/5/25	8.90			Yes
1/6/25	9.08			Yes
1/7/25	8.93			Yes
1/8/25	8.93			Yes
1/9/25	8.88			Yes
1/10/25	8.82			Yes
1/11/25	8.82	27.6		Yes
1/12/25	8.87			Yes
1/13/25	8.77			Yes
1/14/25	8.89			Yes
1/15/25	8.98			Yes
1/16/25	9.01			Yes
1/17/25	9.00	24.2		Yes
1/18/25	8.84			Yes
1/19/25	8.83			Yes
1/20/25	8.82			Yes
1/21/25	8.99			Yes
1/22/25	8.89			Yes
1/23/25	8.91			Yes
1/24/25	8.91	26.8		Yes
1/25/25	8.88			Yes
1/26/25	9.00			Yes
1/27/25	8.86			Yes
1/28/25	8.82			Yes
1/29/25	8.90			Yes
1/30/25	8.92			Yes
1/31/25	8.92	23.8		Yes

Entry Point B

PWSID	4100786
System name	Skyview Acres Water Co-op
Entry Point	EP-B EP City of Sandy
Sample Period	Jan-25
Number of excursionsn during this month (count the number of days when any WQP was less than minimum required)	0
Total excursion during the previous 5 months	0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative	0
For OHA use only	
Minimum Water Quality	
Parameters as set by	State
pH	7.8
Alk	15 Alkanlinity
PO4	Orthrophosphate
Other	
Print Name	David Jacob
Signature	<u>David Jacob</u>
Date	2/5/2025