

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos	other	Y/N
2/1/25	9.05				Yes
2/2/25	9.05				Yes
2/3/25	9.06				Yes
2/4/25	8.88				Yes
2/5/25	8.80				Yes
2/6/25	8.88				Yes
2/7/25	8.87	27.3			Yes
2/8/25	8.86				Yes
2/9/25	8.88				Yes
2/10/25	8.76				Yes
2/11/25	8.89				Yes
2/12/25	8.98				Yes
2/13/25	9.07				Yes
2/14/25	9.03	23.4			Yes
2/15/25	8.90				Yes
2/16/25	8.87				Yes
2/17/25	8.83				Yes
2/18/25	9.04				Yes
2/19/25	9.02				Yes
2/20/25	9.01				Yes
2/21/25	9.09	26.8			Yes
2/22/25	9.14				Yes
2/23/25	9.19				Yes
2/24/25	9.09				Yes
2/25/25	9.17				Yes
2/26/25	9.22				Yes
2/27/25	9.15				Yes
2/28/25	9.07	27.7			Yes

Entry Point B

PWSID	4100786
System name	Skyview Acres Water Co-op
Entry Point	EP-B EP City of Sandy
Sample Period	Feb-25
Number of excursionsn during this month (count the number of days when any WQP was less than minimum required)	0
Total excursion during the previous 5 months	0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative	0
For OHA use only	
Minimum Water Quality	
Parameters as set by	State
pH	7.8
Alk	15 Alkanlinity
PO4	Orthrophosphate
Other	

Print Name David Jacob

Signature David Jacob

Date 3/1/2025