

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
3/1/25	9.0			Yes
3/2/25	9.0			Yes
3/3/25	9.0			Yes
3/4/25	9.1			Yes
3/5/25	9.1			Yes
3/6/25	9.1			Yes
3/7/25	9.1	24.3		Yes
3/8/25	9.0			Yes
3/9/25	9.0			Yes
3/10/25	9.0			Yes
3/11/25	9.1			Yes
3/12/25	9.1			Yes
3/13/25	9.1			Yes
3/14/25	9.2	24.1		Yes
3/15/25	9.1			Yes
3/16/25	9.2			Yes
3/17/25	9.1			Yes
3/18/25	9.0			Yes
3/19/25	8.9			Yes
3/20/25	8.9			Yes
3/21/25	8.9	25.8		Yes
3/22/25	9.0			Yes
3/23/25	9.0			Yes
3/24/25	8.9			Yes
3/25/25	8.7			Yes
3/26/25	8.8			Yes
3/27/25	8.8			Yes
3/28/25	8.8	42.2		Yes
3/29/25	8.8			Yes
3/30/25	8.9			Yes
3/31/25	8.83			Yes

Entry Point B

PWSID 4100786

System name Skyview Acres Water Co-op

Entry Point EP-B EP City of Sandy

Sample Period Mar-25

Number of excursionsn during this month 0
(count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are culmulative 0

For OHA use only

Minimum Water Quality Parameters as set by State

pH 7.8

Alk 15 Alkanlinity

PO4 Orthrophosphate

Other

Print Name David Jacob

Signature David Jacob

Date 4/4/2025