

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
4/1/25	8.92			Yes
4/2/25	8.91			Yes
4/3/25	8.98			Yes
4/4/25	9.04	28		Yes
4/5/25	8.92			Yes
4/6/25	8.80			Yes
4/7/25	8.80			Yes
4/8/25	8.80			Yes
4/9/25	8.95			Yes
4/10/25	8.81			Yes
4/11/25	8.82	24.5		Yes
4/12/25	8.79			Yes
4/13/25	8.83			Yes
4/14/25	8.85			Yes
4/15/25	8.91			Yes
4/16/25	9.00			Yes
4/17/25	8.85			Yes
4/18/25	8.87	35.5		Yes
4/19/25	8.88			Yes
4/20/25	8.87			Yes
4/21/25	8.89			Yes
4/22/25	8.87			Yes
4/23/25	8.82			Yes
4/24/25	8.84			Yes
4/25/25	8.88	22.9		Yes
4/26/25	8.78			Yes
4/27/25	8.70			Yes
4/28/25	8.81			Yes
4/29/25	8.80			Yes
4/30/25	8.83			Yes

Entry Point B

PWSID	4100786
System name	Skyview Acres Water Co-op
Entry Point	EP-B EP City of Sandy
Sample Period	Apr-25
Number of excursionsn during this month (count the number of days when any WQP was less than minimum required)	0
Total excursion during the previous 5 months	0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative	0
For OHA use only	
Minimum Water Quality	
Parameters as set by	State
pH	7.8
Alk	15 Alkanlinity
PO4	Orthrophosphate
Other	

Print Name David Jacob

Signature David Jacob

Date 5/2/2025