

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
5/1/25	8.96			Yes
5/2/25	8.95	22.9		Yes
5/3/25	9.03			Yes
5/4/25	9.02			Yes
5/5/25	8.97			Yes
5/6/25	8.96			Yes
5/7/25	8.97			Yes
5/8/25	8.98			Yes
5/9/25	8.94	27.3		Yes
5/10/25	8.99			Yes
5/11/25	9.01			Yes
5/12/25	8.96			Yes
5/13/25	8.95			Yes
5/14/25	8.95			Yes
5/15/25	8.94			Yes
5/16/25	8.94	24.5		Yes
5/17/25	9.03			Yes
5/18/25	9.00			Yes
5/19/25	9.00			Yes
5/20/25	8.97			Yes
5/21/25	8.98			Yes
5/22/25	8.93			Yes
5/23/25	8.95	28.2		Yes
5/24/25	8.97			Yes
5/25/25	8.99			Yes
5/26/25	8.93			Yes
5/27/25	8.93			Yes
5/28/25	8.92			Yes
5/29/25	8.98			Yes
5/30/25	8.94	29.5		Yes
5/31/25	8.86			Yes

Entry Point B

PWSID	4100786
System name	Skyview Acres Water Co-op
Entry Point	EP-B EP City of Sandy
Sample Period	May-25
Number of excursionsn during this month (count the number of days when any WQP was less than minimum required)	0
Total excursion during the previous 5 months (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative	0
For OHA use only	
Minimum Water Quality	
Parameters as set by	State
pH	7.8
Alk	15 Alkanlinity
PO4	Orthrophosphate
Other	
Print Name	David Jacob
Signature	<i>David Jacob</i>
Date	6/3/2025