

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
6/1/25	8.82			Yes
6/2/25	8.80			Yes
6/3/25	8.84			Yes
6/4/25	8.82			Yes
6/5/25	8.77			Yes
6/6/25	8.91	29.4		Yes
6/7/25	8.91			Yes
6/8/25	8.95			Yes
6/9/25	8.96			Yes
6/10/25	8.97			Yes
6/11/25	8.91			Yes
6/12/25	8.91	32.2		Yes
6/13/25	8.92			Yes
6/14/25	8.97			Yes
6/15/25	8.89			Yes
6/16/25	8.90			Yes
6/17/25	8.95			Yes
6/18/25	8.92			Yes
6/19/25	9.02			Yes
6/20/25	9.02	25.3		Yes
6/21/25	8.99			Yes
6/22/25	8.99			Yes
6/23/25	9.04			Yes
6/24/25	9.03			Yes
6/25/25	9.01			Yes
6/26/25	8.89			Yes
6/27/25	8.80	24.1		Yes
6/28/25	8.78			Yes
6/29/25	8.84			Yes
6/30/25	8.86			Yes

Entry Point B

PWSID 4100786
System name Skyview Acres Water Co-op
Entry Point EP-B EP City of Sandy
Sample Period Jun-25
Number of excursionsn during this month 0
(count the number of days when any WQP was
less than minimum required)
Total excursion during the previous 5 months
(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are 0
culmulative

For OHA use only

Minimum Water Quality
Parameters as set by State
pH 7.8
Alk 15 Alkanlinity
PO4 Orthrophosphate
Other

Print Name David Jacob
Signature David Jacob
Date 7/4/2025