

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
7/1/25	8.8			Yes
7/2/25	8.9			Yes
7/3/25	8.8			Yes
7/4/25	8.9			Yes
7/5/25	8.9	27.2		Yes
7/6/25	9.0			Yes
7/7/25	8.8			Yes
7/8/25	8.8			Yes
7/9/25	8.9			Yes
7/10/25	8.9			Yes
7/11/25	8.9	31.5		Yes
7/12/25	8.9			Yes
7/13/25	8.9			Yes
7/14/25	8.9			Yes
7/15/25	8.9			Yes
7/16/25	9.0			Yes
7/17/25	8.9			Yes
7/18/25	9.0			Yes
7/19/25	7.6	21.8		No
7/20/25	8.9			Yes
7/21/25	8.9			Yes
7/22/25	9.0			Yes
7/23/25	9.0			Yes
7/24/25	9.0			Yes
7/25/25	8.9	30.9		Yes
7/26/25	8.9			Yes
7/27/25	8.9			Yes
7/28/25	8.9			Yes
7/29/25	8.9			Yes
7/30/25	8.9			Yes
7/31/25	8.9			Yes

Entry Point B

PWSID	4100786
System name	Skyview Acres Water Co-op
Entry Point	EP-B EP City of Sandy
Sample Period	Jul-25
Number of excursionsn during this month (count the number of days when any WQP was less than minimum required)	1
Total excursion during the previous 5 months (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative	0
For OHA use only	
Minimum Water Quality	
Parameters as set by	State
pH	7.8
Alk	15 Alkanlinity
PO4	Orthrophosphate
Other	
Print Name	David Jacob
Signature	<i>David Jacob</i>
Date	8/3/2025