

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
8/1/25	8.91	28.2		Yes
8/2/25	8.86			Yes
8/3/25	8.85			Yes
8/4/25	8.86			Yes
8/5/25	8.76			Yes
8/6/25	8.81			Yes
8/7/25	8.84			Yes
8/8/25	8.80			Yes
8/9/25	8.79	24.4		Yes
8/10/25	8.82			Yes
8/11/25	8.81			Yes
8/12/25	8.89			Yes
8/13/25	7.82			Yes
8/14/25	7.88			Yes
8/15/25	9.20	35.4		Yes
8/16/25	8.43			Yes
8/17/25	8.19			Yes
8/18/25	8.54			Yes
8/19/25	8.70			Yes
8/20/25	8.67			Yes
8/21/25	8.69			Yes
8/22/25	8.71	30.9		Yes
8/23/25	8.61			Yes
8/24/25	8.70			Yes
8/25/25	8.70			Yes
8/26/25	8.73			Yes
8/27/25	8.71			Yes
8/28/25	8.79			Yes
8/29/25	8.84	29		Yes
8/30/25	8.87			Yes
8/31/25	8.82			Yes

Entry Point B

PWSID	4100786
System name	Skyview Acres Water Co-op
Entry Point	EP-B EP City of Sandy
Sample Period	Aug-25
Number of excursionsn during this month (count the number of days when any WQP was less than minimum required)	0
Total excursion during the previous 5 months	1
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative	0
For OHA use only	
Minimum Water Quality	
Parameters as set by	State
pH	7.8
Alk	15 Alkanlinity
PO4	Orthrophosphate
Other	
Print Name	David Jacob
Signature	<i>David Jacob</i>
Date	9/1/2025