

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
9/1/25	8.86			Yes
9/2/25	8.91			Yes
9/3/25	8.87			Yes
9/4/25	8.88			Yes
9/5/25	8.79	29		Yes
9/6/25	8.72			Yes
9/7/25	8.53			Yes
9/8/25	8.76			Yes
9/9/25	8.71			Yes
9/10/25	8.64			Yes
9/11/25	8.53			Yes
9/12/25	8.57	27		Yes
9/13/25	8.56			Yes
9/14/25	8.60			Yes
9/15/25	8.46			Yes
9/16/25	8.16			Yes
9/17/25	8.05			Yes
9/18/25	8.09			Yes
9/19/25	8.24	25.9		Yes
9/20/25	8.33			Yes
9/21/25	8.28			Yes
9/22/25	8.39			Yes
9/23/25	8.32			Yes
9/24/25	8.35			Yes
9/25/25	8.24			Yes
9/26/25	8.32	26.2		Yes
9/27/25	8.30			Yes
9/28/25	8.19			Yes
9/29/25	8.03			Yes
9/30/25	8.11			Yes

Entry Point B

PWSID	4100786
System name	Skyview Acres Water Co-op
Entry Point	EP-B EP City of Sandy
Sample Period	Sep-25
Number of excursionsn during this month (count the number of days when any WQP was less than minimum required)	0
Total excursion during the previous 5 months	1
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative	0
For OHA use only	
Minimum Water Quality	
Parameters as set by	State
pH	7.8
Alk	15 Alkanlinity
PO4	Orthrophosphate
Other	
Print Name	David Jacob
Signature	<u>David Jacob</u>
Date	10/5/2025