

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
10/1/25	8.32			Yes
10/2/25	8.36			Yes
10/3/25	8.34	26.3		Yes
10/4/25	8.31			Yes
10/5/25	8.21			Yes
10/6/25	8.15			Yes
10/7/25	8.14			Yes
10/8/25	8.15			Yes
10/9/25	8.27			Yes
10/10/25	8.27	24.2		Yes
10/11/25	8.20			Yes
10/12/25	8.16			Yes
10/13/25	8.17			Yes
10/14/25	8.19			Yes
10/15/25	8.20			Yes
10/16/25	8.21			Yes
10/17/25	8.25	31.4		Yes
10/18/25	8.16			Yes
10/19/25	8.18			Yes
10/20/25	8.16			Yes
10/21/25	8.19			Yes
10/22/25	8.16			Yes
10/23/25	8.22			Yes
10/24/25	8.26	27.4		Yes
10/25/25	8.21			Yes
10/26/25	8.29			Yes
10/27/25	8.25			Yes
10/28/25	8.32			Yes
10/29/25	8.09			Yes
10/30/25	8.09			Yes
10/31/25	8.03	26.3		Yes

Entry Point B

PWSID	4100786
System name	Skyview Acres Water Co-op
Entry Point	EP-B EP City of Sandy
Sample Period	Oct-25
Number of excursionsn during this month (count the number of days when any WQP was less than minimum required)	0
Total excursion during the previous 5 months	1
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative	0
For OHA use only	
Minimum Water Quality	
Parameters as set by	State
pH	7.8
Alk	15 Alkanlinity
PO4	Orthrophosphate
Other	
Print Name	David Jacob
Signature	<i>David Jacob</i>
Date	11/4/2025