

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
11/1/25	8.44			Yes
11/2/25	8.33			Yes
11/3/25	8.29			Yes
11/4/25	8.35			Yes
11/5/25	8.37			Yes
11/6/25	8.40			Yes
11/7/25	8.37	22.4		Yes
11/8/25	8.31			Yes
11/9/25	8.24			Yes
11/10/25	8.35			Yes
11/11/25	8.37			Yes
11/12/25	8.32			Yes
11/13/25	8.55			Yes
11/14/25	8.60	18		Yes
11/15/25	8.61			Yes
11/16/25	8.64			Yes
11/17/25	8.41			Yes
11/18/25	8.37			Yes
11/19/25	8.04			Yes
11/20/25	8.11			Yes
11/21/25	8.16	40.1		Yes
11/22/25	8.08			Yes
11/23/25	8.13			Yes
11/24/25	8.06			Yes
11/25/25	8.21			Yes
11/26/25	8.48			Yes
11/27/25	8.34			Yes
11/28/25	8.38	31.4		Yes
11/29/25	8.39			Yes
11/30/25	8.36			Yes

Entry Point B

PWSID	4100786
System name	Skyview Acres Water Co-op
Entry Point	EP-B EP City of Sandy
Sample Period	Nov-25
Number of excursionsn during this month (count the number of days when any WQP was less than minimum required)	0
Total excursion during the previous 5 months	1
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative	0
For OHA use only	
Minimum Water Quality	
Parameters as set by State	State
pH	7.8
Alk	15 Alkanlinity
PO4	Orthrophosphate
Other	

Print Name David Jacob

Signature David Jacob

Date 12/7/2025