Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
12/1/25	8.84			Yes
12/2/25	8.81			Yes
12/3/25	8.79			Yes
12/4/25	8.78			Yes
12/5/25	8.77	24.9		Yes
12/6/25	8.78			Yes
12/7/25	8.75			Yes
12/8/25	8.71			Yes
12/9/25	8.74			Yes
12/10/25	8.73			Yes
12/11/25	8.66			Yes
12/12/25	8.80	25.5		Yes
12/13/25	8.79			Yes
12/14/25	8.70			Yes
12/15/25	8.61			Yes
12/16/25	8.56			Yes
12/17/25	8.69			Yes
12/18/25	8.65			Yes
12/19/25	8.81			Yes
12/20/25	8.82			Yes
12/21/25	8.55			Yes
12/22/25	8.50	30		Yes
12/23/25	8.36			Yes
12/24/25	8.48			Yes
12/25/25	8.35			Yes
12/26/25	8.46			Yes
12/27/25	8.42	45.4		Yes
12/28/25	8.34			Yes
12/29/25	8.43			Yes
12/30/25	8.44			Yes
12/31/25	8.58			Yes

Entry Point B

PWSID	4100786	
System name	Skyview Acres Water Co-op	
Entry Point	EP-B	EP City of Sandy
Sample Period	Dec-25	

Number of excursionsn during this month 0

(count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 1

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative 0

For OHA use only

Minimum Water Quality Parameters as set by		DWP
pH	7.8	
Alk	15	Alkanlinity
PO4		Orthrophosphate
Other		

Print Name	David Jacob
Signature	David Jacob
Date	1/5/2026