

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos	other	Y/N
9/1/22					
9/2/22					
9/3/22					
9/4/22					
9/5/22					
9/6/22					
9/7/22					
9/8/22					
9/9/22					
9/10/22					
9/11/22					
9/12/22					
9/13/22					
9/14/22					
9/15/22					
9/16/22					
9/17/22					
9/18/22					
9/19/22					
9/20/22					
9/21/22					
9/22/22					
9/23/22					
9/24/22					
9/25/22	12100 Virginia Ct				
9/26/22	8.23	22.5			Yes
9/27/22					
9/28/22					
9/29/22					
9/30/22					

Distribution system

PWSID 4100786

System name Skyview Acres Water Co-op

Entry Point EP-B EP City of Sandy

Sample Period Sep-22

Number of excursionsn during this month 0
(count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are culmulative

For OHA use only

Minimum Water Quality	
Parameters as set by	State
pH	7.8
Alk	15 Alkanlinity
PO4	Orthrophosphate
Other	

Print Name David Jacob

Signature David Jacob

Date 10/4/2022