

Day	pH	Alk	Phos	Other	Y/N
1	—				
2	—				
3	—				
4	7.6				Y
5	7.8				Y
6	7.7				Y
7	7.9				Y
8	7.9				Y
9					
10					
11	7.6				Y
12	7.8				Y
13	7.7				Y
14					
15	7.6				Y
16					
17					
18	7.6				Y
19	7.6				Y
20	7.7				Y
21	7.6				Y
22	7.9				Y
23					
24					
25					
26	7.7				Y
27	7.7				Y
28					
29	7.9				Y
30	7.7				Y
31	8.0				Y

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

**ENTRY POINT**  
**EP-A**

**PWS ID 4100792**  
**SCAPPOOSE, CITY OF**

Sample period: March/2024  
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2  
 Alk            (Alkalinity)

Print Name: Darryl Sykes  
 Signature: Darryl Sykes  
 Date & Phone#: 4/8/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0