

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

| Day | pH  | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1   | off | —   | —    | —     |     |
| 2   | 8.2 |     |      |       | Y   |
| 3   | off | —   | —    | —     |     |
| 4   | off | —   | —    | —     |     |
| 5   | 7.8 |     |      |       | Y   |
| 6   | 7.8 |     |      |       | Y   |
| 7   | 8.1 |     |      |       | Y   |
| 8   | 8.0 |     |      |       | Y   |
| 9   | 7.9 |     |      |       | Y   |
| 10  | 7.9 |     |      |       | Y   |
| 11  | —   |     |      |       | Y   |
| 12  | 7.9 |     |      |       | Y   |
| 13  | 7.6 |     |      |       | Y   |
| 14  | 7.7 |     |      |       | Y   |
| 15  | 7.8 |     |      |       | Y   |
| 16  | off |     |      |       |     |
| 17  | 7.8 |     |      |       | Y   |
| 18  | off | —   | —    | —     |     |
| 19  | off | —   | —    | —     |     |
| 20  | 8.1 |     |      |       | Y   |
| 21  | 7.8 |     |      |       | Y   |
| 22  | 7.8 |     |      |       | Y   |
| 23  | 8.1 |     |      |       | Y   |
| 24  | 8.1 |     |      |       | Y   |
| 25  | off |     |      |       | Y   |
| 26  | 8.1 |     |      |       | Y   |
| 27  | 8.3 |     |      |       | Y   |
| 28  | 7.7 |     |      |       | Y   |
| 29  | 7.8 |     |      |       | Y   |
| 30  | 7.7 |     |      |       | Y   |
| 31  | 7.7 |     |      |       | Y   |

<<Have  
minimums  
been met for  
this day?

County: Columbia Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100792**

**SCAPPOOSE, CITY OF**

Sample period: JANUARY 2025  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).  
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality  
Parameter(s) as set by State:**

pH 7.2  
Alk            (Alkalinity)

Print Name: Darryl Sykes

Signature: Darryl Sykes

Date & Phone#: 2/5/2025 503-369-0297

Send to DWP within 10 days after end of  
sampling period

(No = N = Excursion) **Total N's** 0