

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5				Y
2	7.5				Y
3	7.4				Y
4	7.5				Y
5	—				
6	7.6				Y
7	7.5				Y
8	—				
9	7.6				Y
10	7.4				Y
11	7.3				Y
12	—				
13	—				
14	7.4				Y
15	7.5				Y
16	7.5				Y
17	7.5				Y
18	7.5				Y
19	7.6				Y
20	7.7				Y
21	7.6				Y
22	7.6				Y
23	7.4				Y
24	7.3				Y
25	7.3				Y
26	8.4				Y
27	7.2				Y
28	7.8				Y
29	7.8				Y
30	7.8				Y
31					

<<Have
minimums
been met for
this day?

County: Columbia Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100792

SCAPPOOSE, CITY OF

Sample period: APRIL / 2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2
Alk (Alkalinity)

Print Name: Darryl Sykes

Signature: Darryl Sykes

Date & Phone#: 5/7/2025 503-369-0297

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0