

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5				Y
2	7.6				Y
3	7.8				Y
4	7.9				Y
5	7.9				Y
6	7.8				Y
7	7.8				Y
8	7.8				Y
9	7.5				Y
10	7.6				Y
11	7.4				Y
12	7.3				Y
13	7.5				Y
14	7.5				Y
15	7.5				Y
16	7.5				Y
17	7.5				Y
18	7.5				Y
19	7.7				Y
20	7.8				Y
21	7.7				Y
22	7.5				Y
23	7.5				Y
24	7.5				Y
25	7.5				Y
26	7.6				Y
27	7.6				Y
28	7.5				Y
29	7.40				Y
30	7.4				Y
31					

<<Have
minimums
been met for
this day?

County: Columbia Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100792

SCAPPOOSE, CITY OF

Sample period:

JUNE/2025

Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH

7.2

Alk

(Alkalinity)

Print Name:

Darryl Sykes

Signature:

Darryl Sykes

Date & Phone#:

7/7/2025 503-369-0297

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's

0