

Day	pH	Alk	Phos	Other	Y/N
1	8.4				
2	8.2				Y
3	8.1				Y
4	8.1				Y
5	8.1				Y
6	8.2				Y
7	8.3				Y
8	8.4				Y
9	8.3				Y
10	8.2				Y
11	8.1				Y
12	7.9				Y
13	7.9				Y
14	7.5				Y
15	7.9				Y
16	7.8				Y
17	7.9				Y
18	7.9				Y
19	7.9				Y
20	8.0				Y
21	8.1				Y
22	8.1				Y
23	8.1				Y
24	8.1				Y
25	8.3				Y
26	8.3				Y
27	8.5				Y
28	8.6				Y
29	8.8				Y
30	Off				
31					

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0 0 7 9 2

System Name: City of Scappoose

Entry Point: A

Sample Period: September 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Kevin Turner

Signature: Kevin Turner

Date: 10/8/2025

Send to DWP within 10 days after end of sampling period