

Day	pH	Alk	Phos	Other	Y/N
1	8.1				Y
2	8.6				Y
3	8.3				Y
4	8.1				Y
5	8.0				Y
6	8.1				Y
7	8.1				Y
8	8.0				Y
9	7.9				Y
10	7.8				Y
11	Off				
12	8.0				Y
13	8.0				Y
14	7.9				Y
15	8.0				Y
16	8.0				Y
17	7.8				Y
18	7.9				Y
19	7.8				Y
20	7.9				Y
21	7.9				Y
22	7.9				Y
23	7.8				Y
24	7.8				Y
25	7.8				Y
26	7.7				Y
27	7.8				Y
28	7.8				Y
29	8.0				Y
30	7.9				Y
31	7.9				Y

(No = N = Excursion) **Total N's**

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41- 00792

System Name: City of Scappoose

Entry Point: A

Sample Period: October 2025

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality
Parameters as set by

pH

Alk
(Alkalinity)

Print Name: Kevin Turner

Signature: *Kevin Turner*

Date: November 6, 2025

Send to DWP within 10 days after end of
sampling period