

Day	pH	Alk	Phos	Other	Y/N
1	Off				
2	7.9				Y
3	7.8				Y
4	8.0				Y
5	7.4				Y
6	8.0				Y
7	Off				
8	8.0				Y
9	Off				
10	7.9				Y
11	Off				
12	8.0				Y
13	7.9				Y
14	7.9				Y
15	Off				
16	7.9				Y
17	7.9				Y
18	7.8				Y
19	7.9				Y
20	7.9				Y
21	8.0				Y
22	Off				
23	7.9				Y
24	7.9				Y
25	7.9				Y
26	7.8				Y
27	7.8				Y
28	7.8				Y
29	7.8				Y
30	off				
31					

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day?

ENTRY POINT A

PWS ID: 41- 00792

System Name: City of Scappoose

Entry Point: A - Keys

Sample Period: November2025

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk *(Alkalinity)*

Print Name: Kevin Turner

Signature: *Kevin Turner*

Date: December 9, 2025

Send to DWP within 10 days after end of sampling period