

Day	pH	Alk	Phos	Other	Y/N
1	7.8				Y
2	7.8				Y
3	Off				
4	7.7				Y
5	7.9				Y
6	7.9				Y
7	Off				
8	7.8				Y
9	7.8				Y
10	7.8				Y
11	Off				
12	7.8				Y
13	7.9				Y
14	7.8				Y
15	7.8				Y
16	7.8				Y
17	Off				
18	7.8				Y
19	Off				
20	7.7				Y
21	7.7				Y
22	7.6				Y
23	7.6				Y
24	7.7				Y
25	7.7				Y
26	7.7				Y
27	7.5				Y
28	7.7				Y
29	7.6				Y
30	7.7				Y
31	off				

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41- 00792

System Name: City of Scappoose

Entry Point: A

Sample Period: January 2026

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
Alk *(Alkalinity)*

Print Name: Kevin Turner

Signature:

Date and Phone:

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**