

Day	pH	Alk	Phos	Other	Y/N
1	7.3	126			Y
2	off				
3	off				
4	off				
5	off				
6	off				
7	off				
8	off				
9	off				
10	off				
11	off				
12	off				
13	off				
14	off				
15	off				
16	off				
17	7.4	128			Y
18	7.4				Y
19	off				
20	off				
21	off				
22	off				
23	off				
24	off				
25	off				
26	off				
27	off				
28	off				
29	7.2	120			Y
30	7.5				Y
31					

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

ENTRY POINT
EP-B

PWS ID 4100792
SCAPPOOSE, CITY OF

Sample period: APRIL 2024
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2
 Alk 90.0 (Alkalinity)

Print Name: Darryl Sukes
 Signature: Darryl Sukes
 Date & Phone#: 5/6/2024 503-369-0297

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0