



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	off				
2	off				
3	off				
4	7.4				Y
5	off				
6	7.4	128			Y
7	7.5				Y
8	off				
9	off				
10	off				
11	off				
12	off				
13	off				
14	7.3				Y
15	off				
16	off				
17	7.2	124			Y
18	off				
19	off				
20	7.3				Y
21	7.3				Y
22	off				
23	off				
24	off				
25	off				
26	off				
27	off				
28	off				
29	off				
30	7.4	119			Y
31	7.2				Y

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

ENTRY POINT EP-B

PWS ID 4100792
SCAPPOOSE, CITY OF

Sample period: MAY 2024
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH	7.2
Alk	90.0 (Alkalinity)

Print Name: Darryl Sykes
Signature: Darryl Sykes
Date & Phone#: 6/4/2024 503-369-0297

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0