



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.2				Y
2	7.3	132			Y
3	7.5				Y
4	7.4	130			Y
5	7.3				Y
6	7.4				Y
7	7.5				Y
8	7.3	128			Y
9	7.3				Y
10	—				
11	7.6				Y
12	—				
13	7.5				Y
14	—				
15	—				
16	7.4	130			Y
17	—				
18	—				
19	—				
20	7.5				Y
21	—				
22	7.4				Y
23	—				
24	7.2				Y
25	7.2				Y
26	7.5	134			Y
27	—				
28	—				
29	7.8				Y
30					
31					

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

### ENTRY POINT

**EP-B**

**PWS ID 4100792**

**SCAPPOOSE, CITY OF**

Sample period: SEPTEMBER 2024  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

#### Reference

**Minimum Water Quality  
Parameter(s) as set by State:**

pH 7.2  
Alk 90.0 (Alkalinity)

Print Name: Darryl Sykes  
Signature: Darryl Sykes  
Date & Phone#: 10/10/2024 503-369-0297

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0