

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.6	129			Y
3	7.6				Y
4	7.6				Y
5	7.6				Y
6	7.7				Y
7	7.6				Y
8	7.8				Y
9	7.5	126			Y
10	7.6				Y
11	7.7				Y
12	7.8				Y
13	7.8				Y
14	7.6				Y
15	7.8				Y
16	7.6				Y
17	7.6	126			Y
18	7.6				Y
19	7.6				Y
20	7.5				Y
21	7.6				Y
22	7.8				Y
23	7.6				Y
24	7.4				Y
25	7.4				Y
26	7.4				Y
27	7.6				Y
28	7.6	124			Y
29	7.6				Y
30	7.6				Y
31					

(No = N = Excursion) **Total N's** 0

<<Have
minimums
been met for
this day?

County: Columbia Agency: REGION 1

ENTRY POINT

EP-B

PWS ID 4100792

SCAPPOOSE, CITY OF

Sample period: APRIL/2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2
Alk 90.0 (Alkalinity)

Print Name: Darryl Sykes
Signature: Darryl Sykes
Date & Phone#: 5/7/2025 503-369-0297

Send to DWP within 10 days after end of
sampling period