

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.6	122			Y
3	7.6				Y
4	7.5				Y
5	7.6				Y
6	7.6				Y
7	7.5				Y
8	7.8				Y
9	7.6				Y
10	OFF				
11	OFF				
12	OFF				
13	OFF				
14	OFF				
15	OFF				
16	OFF				
17	OFF				
18	OFF				
19	OFF				
20	OFF				
21	OFF				
22	OFF				
23	OFF				
24	OFF				
25	OFF				
26	OFF				
27	7.6				Y
28	OFF				
29	OFF				
30	OFF				
31	OFF				

(No = N = Excursion) **Total N's** 0

<<Have
minimums
been met for
this day?

County: Columbia Agency: REGION 1

ENTRY POINT

EP-B

PWS ID 4100792

SCAPPOOSE, CITY OF

Sample period: MAY / 2025

Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2
Alk 90.0 (Alkalinity)

Print Name: Darryl Sykes

Signature: Darryl Sykes

Date & Phone#: 6/6/2025 503-369-0297

Send to DWP within 10 days after end of
sampling period